

Thurs. 11:00am 6/17

LTR 5-26-04

Facility Summary for R10 Facility ID # 4260087

Owner Name and Address: R H SMITH DIST CO, INC

315 E WINE COUNTRY RD P.O. Box 6 Grandview 98930
509-882-3377

Location Name	Location Street Address	Location City	Zip
4260087 SMITTYS CONOCO	102 E TOPPENISH AVE	Toppenish	98948

Tank ID	Installed	Product	Tank Mat'l of Construction	Piping Material	Piping Type	Tank Release Detection	FR Met
Status	Age (yr)	Capacity	Secondary Option	Secondary Option		Piping Release Detection	Spill/Over/CP
001	1/1/1974	Gasoline	Cathodically Protected Steel	Galvanized Steel	Pressurized	A B C D E F G H J K L	Yes
Currently in Use	30	8,000	Lined Interior	Cathodically Protected		B E F G H J K L	Yes Yes Yes
002	1/1/1974	Gasoline	Cathodically Protected Steel	Galvanized Steel	Pressurized	A B C D E F G H J K L	Yes
Currently in Use	30	6,000	Lined Interior	Cathodically Protected		B E F G H J K L	Yes Yes Yes
003	1/1/1976	Gasoline	Cathodically Protected Steel	Galvanized Steel	Pressurized	A B C D E F G H J K L	Yes
Currently in Use	28	4,000	Lined Interior	Cathodically Protected		B E F G H J K L	Yes Yes Yes

Loc # 509-865-5909 ✓
Contact Susan Smith

Last 3-23-99 RC

Call 11:10 = RH Smith Distributing
(509) 882-3377 - Sue Smith
Dan - Eric - A Harrah - Maintenance
Eddie -

Called 2/7 9:37am

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed